



INDUSTRIAL WATER USE INSPECTION REPORT
(OIL AND GAS EXPLORATION, PRODUCTION, PROCESSING AND REFINING)

DATE:	February 12, 2003	COMPANY REP:	Mike Prichuk
LICENSEE:	Petro-Canada	LICENCE NUMBER:	NFL1-1788/Nuna I-30

WATER SUPPLY:

Source:	Lake #60	Quantity Used:	Refer to Records	Meter Rtg:	By Truckload
---------	----------	----------------	------------------	------------	--------------

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable N/I - Not Inspected

Intake Facilities	A	Storage Structures	A	Treatment Systems	A	Recycling	N/A
Flow Meas. Device	A	Conveyance Lines	N/A	Pumping Stations	A	Modifications	N/A

Comments: Water truck intake hose had screen. Treatment facility had cobalt filters + 2 other screen filters (1 micron). No chlorine used due to waste treatment facility.

WASTE DISPOSAL:

Well Wastes:	Drilling Sump	A	Off-Site Removal	X	Downhole	N/I	Landspread	N/A
Sewage:	Sewage Treat.	A	Camp Sump	A	Natural Water Body	N/A	Wetlands Treat.	N/A
	Continuous		Inter. Discharge					
Solid Waste:	Open Dump	N/A	Landfill	N/A	Burn & Bury Remove	A	Sludge Disposal	A

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable N/I - Not Inspected

Discharge Quality	UNKNOWN	Conveyance Lines	N/A	Disch. Meas. Dev.	A	Freeboard	A
Decant Process	N/A	Sump Treatment	N/A	Dykes, Berms	A	Seepages	N/A
Sump Liners	N/A	Runoff Diversion	N/A	Erosion	N/A	Spills	See Files

Effluent Discharge Rate:	Monitored by Licensee.	SNP Samples Collected:	Yes (By Licensee)
--------------------------	------------------------	------------------------	-------------------

Comments: Licensee just drilling in overburden. The licensee is using an RBC unit with a filter box unit to treat sewage. Samples from SNP#1788-1 have been done. Results have not been submitted to date. Sewage is being deposited into the camp sump. Sludge being incinerated.

GENERAL CONDITIONS:

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable N/I - Not Inspected

Maintenance	A	Records & Reporting	A	Surveillance Network Program (SNP)	A
Geotechnical Inspection	N/A	Posting of Facilities	A	Contingency Plan	Being Reviewed
A & R Plan		Modifications	N/A	Final Product Shipping	A
Groundwater Discharge	N/A	Chemical Storage	A	Annual Report	Due March 31/2002

Comments: Lease area very well organized & clean. Water & Sewage facilities were very clean & well kept.

Violation(s) of Act and/or Licence: NIL

General Comments: Please ensure that copies of the sample results for the sewage effluent are sent to this office. Fax 777-2090-

Additional Comments Attached:	Yes	No	X
-------------------------------	-----	----	---

Inspector's Signature: Rob Walker
Licensee Representative's Title: Drill Supervisor

Inspector's Title: A/Water Resource Officer
Licensee Representative's Signature: N/A