



Taiga Environmental Laboratory
4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9
Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:
190433

- FINAL REPORT -

Prepared For: GNWT - Environment and Natural Resources

Address: P.O. Box 2749
Inuvik, NT
X0E 0T0

Attn: Lloyd Gruben

Facsimile: (867) 678-6659

Final report has been reviewed and approved by:

Glen Hudy
Quality Assurance Officer

NOTES:

- Test methods and data are validated by the laboratory's Quality Assurance Program. Taiga Environmental Laboratory is accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) to ISO/IEC 17025 as a testing laboratory for specific tests registered with CALA.
- Routine methods are based on recognized procedures from sources such as
 - Standard Methods for the Examination of Water and Wastewater APHA AWWA WEF;
 - Environment Canada
 - USEPA
- Samples shall be kept for thirty (30) days after the final report is issued. All microbiological samples shall be disposed of immediately upon completion of analysis to minimize biohazardous risks to laboratory personnel. Please contact the laboratory if you have any special requirements.
- Final results are based on the specific tests at the time of analysis and do not represent the conditions during sampling.

ReportDate: Thursday, July 11, 2019

Print Date: *Thursday, July 11, 2019*

Page 1 of 4



Taiga Environmental Laboratory
4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9
Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:
190433

- CERTIFICATE OF ANALYSIS -

Client Sample ID: **0714-2**

Taiga Sample ID: **001**

Client Project:

Sample Type: Water

Received Date: 28-Jun-19

Sampling Date: 26-Jun-19

Sampling Time: 14:20

Location:

Report Status: Final

Test Parameter	Result	Detection Limit	Units	Analysis Date	Analytical Method *	Qualifer
<u>Inorganics - Nutrients</u>						
Biochemical Oxygen Demand	27	2	mg/L	28-Jun-19	SM5210:B	
<u>Inorganics - Physicals</u>						
pH	8.77		pH units	28-Jun-19	SM4500-H:B	
Solids, Total Suspended	55	3	mg/L	03-Jul-19	SM2540:D	
<u>Microbiology</u>						
Coliforms, Fecal	2400	100	CFU/100mL	28-Jun-19	SM9222:D	
<u>Organics</u>						
Oil and Grease, visible	Non-visible			28-Jun-19	Visual Exam	

ReportDate: Thursday, July 11, 2019

Print Date: Thursday, July 11, 2019

Page 2 of 4



Taiga Environmental Laboratory
4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9
Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:
190433

- CERTIFICATE OF ANALYSIS -

Client Sample ID: **0714-3**

Taiga Sample ID: **002**

Client Project:

Sample Type: Water

Received Date: 28-Jun-19

Sampling Date: 26-Jun-19

Sampling Time: 13:40

Location:

Report Status: Final

Test Parameter	Result	Detection Limit	Units	Analysis Date	Analytical Method *	Qualifer
<u>Inorganics - Nutrients</u>						
Biochemical Oxygen Demand	5	2	mg/L	28-Jun-19	SM5210:B	
<u>Inorganics - Physicals</u>						
pH	8.39		pH units	28-Jun-19	SM4500-H:B	
Solids, Total Suspended	14	3	mg/L	03-Jul-19	SM2540:D	
<u>Microbiology</u>						
Coliforms, Fecal	< 1	1	CFU/100mL	28-Jun-19	SM9222:D	
<u>Organics</u>						
Oil and Grease, visible	Non-visible			28-Jun-19	Visual Exam	

ReportDate: Thursday, July 11, 2019

Print Date: Thursday, July 11, 2019

Page 3 of 4