



MUNICIPAL WATER USE INSPECTION FORM

DATE: SEPTEMBER 30, 1996 COMPANY REP: PETER NAGOSAK, Elsa Komeak
LICENSEE: HAMLET OF TURKTOYAKTIUK LICENCE #: N713-0714

WATER SUPPLY

Source (s): KUDALAK LAKE Quantity Used (to date): unknown
Owner/Operator: HAMLET (estimate or actual)

Indicate: **A - Acceptable** **U - Unacceptable** **N/A - Not Applicable**

Intake Facilities: A Storage Structure A Treatment Systems A Chem. Storage A

Flow Meas. Device A Convey. Lines A Pumping Stations A

Comments: Treatment Plant neat + tidy. Samples taken at SNP 714-1. No problems noted with water supply.

WASTE DISPOSAL

Sewage Sewage Treatment System (primary, secondary or tertiary) primary

Natural Water body X Continuous Discharge (land or water) no

Seasonal Discharge X Wetlands Treatment no Trench no

Solid Waste: Owner/Operator: Hamlet

Landfill X Burn & Landfill _____ Other _____

Indicate: **A - Acceptable** **U - Unacceptable** **N/A - Not Applicable**

Disch. Quality A Decant Structure A Erosion N/A

Disch. Meas. Dev. A Dyke Inspection A Seepages N/A

Dams, Dykes A Freeboard A Spills None reported

Construction A O & M Plan U - revision not received A & R Plan N/A

Periods of Discharge: A Effluent Discharge Rate: ≈ 20 L/sec

Comments: Hamlet doing annual decant of sewage lagoon at time of inspection. Honey bag pit not posted.

FUEL STORAGE

Owner: N/A Operator _____ Condition of Tanks _____

Berms & Liners _____ Water within berm: _____ Evidence of Leaks: _____

Drainage Pipes _____ Pump Station and Catchment Berm _____

Pipeline Condition _____ Not Applicable: _____

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) Took samples at SNP 714-2 prior to decanting and in the middle
(DIAND) Sampled at SNP 714-1, 714-2 and 714-3.

Signs Posted: SNP only 714-1 - water supply Warning, no

Record & Reporting More information required in Annual Report

Geotechnical Inspection: N/A

Non-Compliance of Act or Licence: Part B, item 5; No SNP signs at 714-2 and 714-3

Part B, item 6; No sign at sewage lagoon and honey bag pit.

Part H, item 1; O & M Plan for Sewage + Solid Waste Facilities not received yet.

Page 2 attached Yes _____ No X

Elsa Komeak - A/SAO
Licensee Representatives Title

Elsa Komeak
Licensee Representatives Signature

Scott Gallupe
Inspectors Name

[Signature]
Inspectors Signature