

From: Rigal, Kyna
Sent: Monday, February 17, 2003 12:53 PM
To: 'msemmler@irc.inuvialuit.com'
Cc: Taylor, Tim R. Cgy; Hunt, John; Alistair Sims (E-mail); Di Quinzio, Lino; MACDENG; Osmak, Glenn; Peterson, Barry; Wray Adams (E-mail)
Subject: Nuna I-30 effluent spill

Dear Mardy,

Thank you for speaking with John Hunt and me on Friday with respect to the spill at Nuna I-30. As we discussed, 24 m3 of effluent was discharged into the drilling sump instead of the effluent sump. The effluent is meeting criteria as outlined in the water permit (licence No. N7L1-1788).

As per your request, here is a summary of the recent analytical from the Nuna I-30 effluent:

Effluent

Parameter	Criteria	5-Feb	6-Feb
BOD (mg/L)	80	26	22
TSS (mg/L)	100	14	45
pH	6 to 9	7	7.2
Fecal Coliforms (mg/L)	100	<1	34
Oil and Grease (mg/L)	5	<1	1

An N.W.T. Spill Report has been submitted.

If you need further information please do not hesitate to contact me directly at (403) 296-6368.

Sincerely,
Kyna

Kyna A. Rigal
Petro-Canada, EHS & Stakeholder Relations
Environmental Advisor
150 6 Avenue S.W.
Calgary, AB T2P 3E3
phone: (403) 296-6368
fax: (403) 296-5147